

**STRONGDOR LIMITED  
OAKWOOD WAY  
LA5 9FD LANCASTER  
UNITED KINGDOM**

Maizières-lès-Metz, the 10<sup>th</sup> September 2024

## TEST ASSESSMENT n° EFR-23-S-003496

---

*This document is only informative; only the test report EFR-23-S-0003496 will confirm the results of double leaf and single leaf doorset of reference STRONGDOR S42 and S43.*

**Object** : **Smoke control test of a single leaf doorset (S42) and a double leaf doorset (S43) with overall dimensions of 1242 x 2703 mm (w x h) (S42) and 2395 x 2703 (w x h) (S33) according to norm EN 1634-3: 2004 + AC: 2006 " Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware - Part 3: smoke control test for door and shutter assemblies".**

**Test n°** : **EFR - 23 - S - 003496**

**Performed on** : **MARCH 6<sup>th</sup> and 7<sup>th</sup>, 2024**

**Sponsor** : **STRONGDOR LIMITED  
OAKWOOD WAY  
LA5 9FD LANCASTER  
UNITED KINGDOM**

**Regarding** : We confirm that a smoke control test of a single leaf doorset of reference S42 and a double leaf doorset of reference S43 was made in our Laboratory on March 6<sup>th</sup> and 7<sup>th</sup>.

Smoke control criteria were respected at ambient temperature.

A test report n° EFR-23.-S-003496 has been written and delivered to you on June 10<sup>th</sup> 2024.

**Reached classification\*** : **Sa<sub>4</sub>**  
(for information)

\* : The classification would be precise in a classification document but not in the test report